

# CATARAQUI BAY WASTEWATER TREATMENT PLANT



## 2018 ANNUAL REPORT

## Table of Contents

<b>REPORT CHECK LIST</b> .....	<b>3</b>
<b>EXECUTIVE SUMMARY</b> .....	<b>4</b>
<b>PLANT OVERVIEW</b> .....	<b>5</b>
SEPTAGE RECEIVING .....	5
GRIT REMOVAL .....	5
SCREENING .....	6
FLOW SPLITTING.....	6
PRIMARY SETTLING .....	6
AERATION .....	6
FINAL SETTLING.....	6
DISINFECTION .....	6
OUTFALL.....	7
SLUDGE THICKENING .....	7
BIOSOLIDS MANAGMENT .....	7
BIOSOLIDS DEWATERING.....	7
<b>PLANT PERFORMANCE</b> .....	<b>8</b>
TABLE 1: EFFLUENT RESULTS.....	8
TABLE 2: EFFLUENT LIMITS .....	8
TABLE 3: MONTHLY EFFLUENT PARAMETERS .....	9
TABLE 4: ANNUAL PLANT FLOWS.....	9
TABLE 5: ANNUAL EFFLUENT RESULTS .....	10
<b>MAINTENANCE</b> .....	<b>10</b>
<b>CAPITAL WORKS</b> .....	<b>10</b>
<b>OPERATIONS</b> .....	<b>11</b>
<b>BIOSOLIDS MANAGEMENT</b> .....	<b>11</b>
TABLE 6: BIOSOLIDS RECIPIENTS IN 2018.....	12
<b>EQUIPMENT CALIBRATIONS</b> .....	<b>12</b>
<b>BYPASS SUMMARIES</b> .....	<b>12</b>
TABLE 7: BYPASS EVENTS .....	13
TABLE 8: BYPASS SAMPLING .....	14
BYPASS RESULT INTERPRETATIONS.....	14
<b>APPENDIX A – MONITORED PARAMETERS RESULTS AND GRAPHS</b> .....	<b>14</b>

## REPORT CHECK LIST

Annual report submitted for the Environmental Compliance Approval number 4163-ACPPRK.

Condition 11(6) the first annual report shall cover the period from the commencement of operation of the sewage works to the end of the calendar year and shall be submitted within sixty (60) days following the end of such reporting period. Each subsequent annual report shall be submitted within sixty (60) days following the end of the calendar year being reported upon.

Condition 11(6)(a)to(l).Each annual report shall contain at least the following information:

- Executive Summary
- Tabulation and comprehensive interpretation of all monitoring data and analytical results collected during the reporting period, and a comparison to the effluent quality and quantity
- Summary of all maintenance carried out on any major structure, equipment, apparatus, mechanism or thing forming part of the works
- Description of all operating problems encountered and corrective actions taken during the reporting period
- Tabulation of the volume of sludge generated in the reporting period and an outline of anticipated volumes to be generated over the next reporting period, and an outline of the sludge handling methods and disposal areas to be utilized over the next reporting period
- Evaluation of the calibration and maintenance procedures conducted on all monitoring equipment
- Summary of effluent quality assurance or control measures under taken
- Summary of any complaints
- Summary of all by-passes
- Evaluation for the need for modifications to the works to improve performance and reliability and to minimize upsets and bypasses

## EXECUTIVE SUMMARY

The Cataraqui Bay Wastewater facility was compliant with all concentrations, loadings, sampling and maintenance as required in environmental compliance approval 4163-ACPPRK. A sample for acute lethality collected on June 20, 2018 indicated a high mortality rate for Rainbow trout. SAC was notified and additional sampling was conducted which resulted in no mortality of rainbow trout which indicated the effluent water was of good quality. Additional details can be found in the tables contained in Appendix A.

Average flows through the plant decreased slightly in 2018 showing average flows of 29,009 m<sup>3</sup>/day.

Plant staff continue to maintain operations during the facility upgrades and have continued with planned and reactive maintenance as well as capital works at both the facility and within the associated collection system. Details regarding these improvements are located in the report.


We have continued to provide additional training to staff at the facility to increase their knowledge of the process upgrades currently underway.

The facility saw six secondary bypass events at the Cataraqui Bay Wastewater Treatment Plant and four bypass events within the Kingston West Sewage Collection System in the 2018 reporting year. All by-pass details are listed in Table 7, the Bypass Summary section of this report. All the bypasses except for one (which was due to an unplanned power outage) were due to heavy rainfall events.

Our operation and maintenance staff have continued to assist and support various educational institutions in the area with facility tours, work placements and apprenticeship time.

## PLANT OVERVIEW

The following is a process overview and description of the treatment steps taken at the Cataraqui Bay wastewater treatment plant.



### Septage Receiving

Septage was received at the Cataraqui Bay wastewater plant via local septic truck haulers up to October of 2016. The septage building was decommissioned in October 2016 to make room for upgrades at Cataraqui Bay Wastewater Treatment Plant. There is now a temporary septage station at Ravensview Wastewater Treatment Plant.

### Grit Removal

The first step in the treatment process is grit removal. This is accomplished by the introduction of air at the bottom of the grit channel. The heavier solids in the wastewater will settle to the bottom of the tank, while the organics required to be treated stay in suspension and move on to the next treatment step.

## **Screening**

The second operation is the removal of large particles and floating debris such as wood, rags and plastics from the raw water. These items are removed through mechanical screens that rake the debris from the wastewater stream and onto a belt conveyor.

## **Flow Splitting**

The screened wastewater discharges into a channel where a flow splitter divides the flow into two separate channels that lead to both C and D plants. The channels are equipped with motorized gate valves to control the flow rate to each plant.

## **Primary Settling**

The heavier organics settle by gravity to the bottom of the primary clarifiers and form a sludge blanket on the bottom of the tank. The settled sludge is collected by longitudinal collector flights and scraped into a hopper at the end of the tank. The settled sludge is then pumped to digestion facilities for further treatment. As wastewater is discharged from the primary clarifiers, it is dosed with aluminum sulphate for phosphorus removal.

## **Aeration**

Aeration is the biological process that involves the assimilation of organic insoluble and soluble matter by the action of micro-organisms. The micro-organisms flourish under stable conditions of respiration through air supply and food provided by the primary clarifier effluent. The aeration process effectively removes 95% of the biochemical oxygen demand from the incoming wastewater.

## **Final Settling**

After the assimilation is completed in the aeration tanks, the mixed liquor from these tanks flows into the final clarifiers for solid-liquid separation. The biomass formed in the aeration tanks settles to the bottom of the final clarifiers, where a portion is returned to the head of the aeration tanks to continue assimilation of the food in the primary effluent and the remainder is pumped to sludge thickening facilities.

## **Disinfection**

The supernatant effluent from the final clarifiers is then directed to the disinfection facilities. Chlorine is dosed to the wastewater just prior to entering the chlorine contact tank where disinfection of the final effluent occurs. Just after exiting the chlorine contact tank the wastewater is dosed with calcium thiosulphate for de-chlorinating to ensure no chlorine remains in the water entering the receiving stream.

## **Outfall**

The disinfected effluent from the chlorine contact tank after de-chlorinating is discharged back to Lake Ontario through a 1500mm and a 900mm outfall sewer. The diffusers at the ends of the sewer lines are located 25m offshore and 16m below water surface level.

## **Sludge Thickening**

The sludge thickening facility consists of two rectangular holding tanks, dual rotating drum thickeners and a polymer system. Sludge is thickened from 0.5% solids to approximately 3.5% solids before being pumped to the digester facilities.

## **Biosolids Management**

The sludge from the primary and final clarifiers as well as the sludge from the thickening process is pumped to the digestion facilities. The digester facilities consist of one primary digester, one secondary digester and a holding tank. In the primary digester the sludge is heated, mixed and re-circulated under controlled anaerobic conditions. The anaerobic digestion process produces gas and biosolids. The gas produced is rich in methane which is used as fuel for the boiler system which in turn provides heat for the digestion process. The biosolids produced through sludge digestion are dewatered and used on agricultural lands as a nutrient and soil conditioner when weather and crop conditions permit.

## **Biosolids Dewatering**

The biosolids produced through digestion are dewatered through centrifugation. The centrifuged cake produced is land applied when weather and crops permit. Since January 2018, liquid sludge has been hauled from Cataraqui Bay WWTP to Ravensview WWTP for processing due to site construction.



## PLANT PERFORMANCE

The enclosed performance assessment summarizes and confirms the facility's compliance. Refer to appendix A for detailed tables and graphs for various parameter results.

All effluent quality and quantity parameters outlined in conditions 6 and 7 of environmental compliance approval number 3714-9YURZF were compiled during the reporting period of 2018.

The following tables summarize the results obtained through monitoring of plant performance in accordance with conditions 6 and 7 of the environmental compliance approval number 3714-9YURZF. Effluent objective and limits for environmental compliance approval number 4163-ACPPRK will become effective once the facility upgrades are complete.

**Table 1: Effluent Results**

Effluent Objectives		
Effluent Parameter	Objective (mg/l)	2018 Results (avg.)
CBOD <sub>5</sub>	15.0	5 mg/l
Total suspended solids (TSS)	15.0	6 mg/l
Total Phosphorus	1	0.40 mg/l
Total Chlorine Residual	<0.02	0.01 mg/l
E. Coli (Monthly Geometric Mean Density)	200 counts/ 100 ml	32 counts/ 100 ml

**Table 2: Effluent Limits**

Effluent Limits			
Effluent Parameter	Concentration Limit (mg/l)	Loading Limit from effluent (kg/d)	2018 annual average (kg/d)
CBOD <sub>5</sub>	25.0	970	295
Suspended solids (TSS)	25.0	970	181
Total Phosphorus	1.0	39	11.9
Total Chlorine Residual	0.02		0.01



**Table 3: Monthly Effluent Parameters**

<b>Maximum Monthly Comparison of Effluent 2018</b>				
<b>Month</b>	<b>CBOD5 max concen/max loading (mg/L_kg/day)</b>	<b>TSS max concen/max loading (mg/L_kg/day)</b>	<b>TP max concen/max loading (mg/L_kg/day)</b>	<b>E. coli (Monthly geometric mean density)</b>
January	4mg/L_100kg/day	6mg/L_200kg/day	0.49mg/l_17kg/day	10
February	5mg/L-200kg/day	10mg/L_500kg/day	0.47mg/l_133kg/day	140
March	5mg/L-100kg/day	4mg/L_100kg/day	2.55mg/l_97.6kg/day	10
April	8mg/L-300kg/day	11mg/L_610kg/day	0.23mg/l_26kg/day	100
May	12mg/L-370kg/day	70mg/L_2000kg/day	0.60mg/l_22kg/day	393
June	3mg/L-70kg/day	7mg/L_200kg/day	0.65mg/l_15kg/day	6
July	6mg/L-100kg/day	5mg/L_90kg/day	0.61mg/l_17kg/day	6
August	23mg/L-570kg/day	11mg/L_330kg/day	0.49mg/l_17kg/day	30
September	13mg/L-270kg/day	12mg/L_310kg/day	0.69mg/l_17kg/day	10
October	6mg/L-200kg/day	5mg/L_100kg/day	0.64mg/l_15kg/day	96
November	23mg/L-630kg/day	16mg/L_440kg/day	0.84mg/l_30kg/day	44
December	6mg/L-200kg/day	5mg/L_200kg/day	0.44mg/l_15kg/day	16

**Table 4: Annual Plant Flows**

<b>Plant Flows (m<sup>3</sup>/day)</b>							
<b>Parameter</b>	<b>2012</b>	<b>2013</b>	<b>2014</b>	<b>2015</b>	<b>2016</b>	<b>2017</b>	<b>2018</b>
Avg. m <sup>3</sup> /day	25374	26721	27145	26147	26072	30042	28963
Max. m <sup>3</sup> /day	56579	78981	90801	56583	67405	121860	94957
Design. M <sup>3</sup> /day	38800	38800	38800	38800	38800	38800	38800
% (daily/design)	65.4%	68.9%	70.0%	67.4%	67.2%	77.4%	74.6%

**Table 5: Annual Effluent Results**

Final Effluent Parameter Results								
Parameter (mg/L)	2012	2013	2014	2015	2016	2017	2018	LIMITS
CBOD <sub>5</sub>	7.86	19.34	6	5.3	4.05	3.13	5	25
Suspended Solids	5.21	5.53	6.2	6.5	4.8	5.09	6	25
Total Phosphorus	0.53	0.57	0.61	0.55	0.51	0.55	0.40	1.0
Total Chlorine	0.00	0.01	0.01	0.01	0.018	0.018	0.01	<0.02
Acute Lethality	n/a	n/a	n/a	All Pass	All Pass	All Pass	5 Pass/ 1 Fail	Pass

Note: Acute lethality testing was started in 2015.

## MAINTENANCE

In 2018 we continued with our preventative maintenance program of vibration testing, oil analysis and electrical surge protection. Preventative maintenance and inspections were performed on most clarifiers during the summer months.

The following bullet points highlight other major projects completed this year.

- Repaired chains and flights for secondary tanks
- Annual infrared scans on HV electrical
- Routine vibration monitoring
- Diesel generator repair & maintenance

## CAPITAL WORKS

In October 2016 work began on plant wide upgrades. During the proposed project completion timeline of 4 years (2016-2020), the Cataraqui Bay Wastewater Treatment Plant will undergo an extensive process, electrical/instrumentation, and mechanical upgrade.

The additional major highlights for capital works in 2018 at the Cataraqui Bay WWTP and associated sewage collection system were:

- Westbrook Pumping Station upgrades and refurbishment
- Environmental Assessment of the Days Rd Pumping Station
- Continued work on the Wastewater Master Plan assessment

## **OPERATIONS**

Preventative maintenance and regular process and equipment inspections lead to operational problems being diagnosed quickly and corrective actions implemented immediately. Non flushable materials such as wipes and grease have become more prominent in the sewer system resulting in some operational and maintenance challenges. Utilities Kingston has implemented a public education program to make customers more aware of what materials should not be flushed down the sewers. This program has included: radio and newspaper campaigns, through social media such as Twitter and Facebook, bill stuffers, information on back of parking tickets, and bus information signs. This has been an ongoing campaign for the past two years with some positive results.

## **BIOSOLIDS MANAGEMENT**

The dewatering facility is the primary method of solids handling at the Cataraqui Bay facility. The secondary digested sludge is dewatered through a centrifuge and then stock piled until land application is available during the summer season.

In January of 2018, the dewatering facility at Cataraqui Bay Sewage Treatment Plant was under construction so liquid sludge was hauled to the Ravensview WWTP for processing. An approximate volume of 29,200m<sup>3</sup> of liquid sludge was transported from Cataraqui Bay Wastewater Treatment Plant to the Ravensview Wastewater Treatment Plant in 2018. With the combination of both Ravensview WWTP and Cataraqui Bay WWTP liquid sludge to process a combined volume of 119,590 m<sup>3</sup> of liquid sludge was processed through the centrifuge, and approximately 14,588 m<sup>3</sup> of sludge cake was stored on site until land applied on licensed agricultural fields. Land application is completed by Smith's Pumping service.

It is too hard to predict exactly where and when we will spread in 2019, as crops and weather will be the major variables that we will be dealing with in the 2019 spreading season. Below are the active C of A's and addresses for the City of Kingston in which spreading can take place.

**Table 6: Biosolids Recipients in 2018**

<u>C Of A and NASM Plan #</u>	<u>Address</u>	<u>Expiry Date</u>
21808	Middle Rd.	31/12/2018
21819	Hamilton Rd.	31/12/2018
21940	SunEdison Property	31/12/2018
22144	McIntyre Rd.	31/12/2019
22243	Multiple Farms (Milligan)	31/12/2019
22281	Haig Rd.	31/12/2019
22383	Brown Rd.	31/12/2020
22685	Multiple Farms	31/12/2020
22694	South Shore Rd.	31/12/2020
22853	Huffman Rd.	31/12/2021
22855	Lake Rd.	31/12/2021
22901	County Rd. 8	31/12/2021
22987	Sunbury Rd.	31/12/2021
23007	County Rd. 4	31/12/2021
23047	Palace Rd.	31/12/2021
23074	Simmons Rd.	31/12/2021
23110	Sunbury Rd.	31/12/2020
23119	Hamilton Rd.	31/12/2021
23215	Sand Hill Rd.	31/12/2021

## **EQUIPMENT CALIBRATIONS**

All of the plant flow meters, online analyzers and lab equipment are calibrated annually by third party contractors. As a result of this proactive approach, the facility saw limited downtime of major equipment and saw very few mechanical or electrical failures this year. Calibration records are available upon request.

## **COMPLAINTS**

There have been no official complaints about the Cataraqui Bay Wastewater Treatment Plant operations for the reporting year 2018.

## **BYPASS SUMMARIES**

Table 7 summarizes the locations, volumes and durations of bypass events for the reporting year 2018. Table 8 summarizes the test results from samples taken during the 2018 bypass events.

**Table 7: Bypass Events**

<b>Bypass Event Record</b>						
<b>Date mm/dd/yyyy</b>	<b>Location</b>	<b>Start Time</b>	<b>Duration (hr + mins)</b>	<b>Volume (m<sup>3</sup>)</b>	<b>Reason For Bypass</b>	<b>Precip (mm)</b>
<b>01/12/2018 – 01/13/2018</b>	<b>Cataraqui Bay WWTP (secondary bypass)</b>	<b>7:45</b>	<b>3:55</b>	<b>5600</b>	<b>Heavy rain/ rapid snow melt</b>	<b>38.1</b>
<b>01/12/2018</b>	<b>Crerar Pumping Station</b>	<b>6:45</b>	<b>21:30</b>	<b>600</b>	<b>Heavy rain/rapid snow melt</b>	<b>38.1</b>
<b>02/20/2018 – 02/21/2018</b>	<b>Cataraqui Bay WWTP (secondary bypass)</b>	<b>08:00</b>	<b>13:45</b>	<b>5600</b>	<b>Heavy rain/snow melt</b>	<b>26.1</b>
<b>02/20/2018</b>	<b>Crerar Pumping Station</b>	<b>13:55</b>	<b>19:30</b>	<b>100</b>	<b>Heavy rain/snow melt</b>	<b>26.1</b>
<b>04/16/2018 – 04/18/2018</b>	<b>Cataraqui Bay WWTP (secondary bypass)</b>	<b>17:38</b>	<b>10:15</b>	<b>20507</b>	<b>Heavy rain/snow melt</b>	<b>30.3</b>
<b>04/16/2018 – 04/17/2018</b>	<b>Crerar Pumping Station</b>	<b>17:15</b>	<b>2:30</b>	<b>851</b>	<b>Heavy rain/snow melt</b>	<b>30.3</b>
<b>05/29/2018</b>	<b>Cataraqui Bay WWTP (secondary bypass)</b>	<b>17:30</b>	<b>21:30</b>	<b>4333</b>	<b>Unplanned power disruption</b>	
<b>11/27/2018 – 11/28/2018</b>	<b>Cataraqui Bay WWTP (secondary bypass)</b>	<b>4:50</b>	<b>3:10</b>	<b>5002</b>	<b>Heavy rain over short period and runoff</b>	<b>11.5</b>
<b>12/22/2018 – 12/23/2018</b>	<b>Cataraqui Bay WWTP (secondary bypass)</b>	<b>18:45</b>	<b>2:30</b>	<b>6606</b>	<b>Heavy rain</b>	<b>65.7</b>
<b>12/21/2018 – 12/22/2018</b>	<b>Crerar Pumping Station</b>	<b>21:00</b>	<b>5:00</b>	<b>122</b>	<b>Heavy rain</b>	<b>65.7</b>

**Table 8: Bypass Sampling**

<b>Bypass Event Sampling Results Annual Average for Cataraqi Bay Wastewater Treatment Plant</b>		
<b>Parameter</b>	<b>Units</b>	<b>Cat. Bay STP Annual Avg.</b>
E coli	Cfu/100mL	20568
CBOD <sub>5</sub>	mg/l	28
TSS	mg/l	79
TP	mg/l	1.75

<b>Bypass Event Sampling Results Annual Average for Crerar Pumping Station</b>		
<b>Parameter</b>	<b>Units</b>	<b>Crerar PS Annual Avg.</b>
E coli	Cfu/100mL	11468
CBOD <sub>5</sub>	mg/l	10
TSS	mg/l	46
TP	mg/l	0.83

**BYPASS RESULT INTERPRETATIONS**

CBOD<sub>5</sub>, TP & TSS results are much the same as typical raw sewage influent to the sewage plant.

**APPENDIX A – MONITORED PARAMETERS RESULTS AND GRAPHS**



# CATARAQUI BAY Wastewater Treatment Plant

## 2018 ANNUAL REPORT


### Monthly data

Month	Units	Raw sewage	Final Effluent	Removal	Raw sewage	Final Effluent	Removal
		CBOD5 mg/L	CBOD5 mg/L	CBOD5 %	Suspended solids mg/L	Suspended solids mg/L	Suspended solids %
JAN.		159.0	2.6	98%	182.0	3.9	98%
FEB.		120.0	4.3	96%	141.0	4.3	97%
MAR.		94.0	2.6	97%	95.0	2.6	97%
APR.		113.0	5.8	95%	138.0	8.8	94%
MAY		119.0	3.8	97%	138.0	14.8	89%
JUN.		146.0	1.8	99%	218.0	4.8	98%
JUL.		189.0	4.3	98%	151.0	3.0	98%
AUG.		160.0	7.0	96%	132.0	5.6	96%
SEP.		178.0	7.5	96%	100.0	6.9	93%
OCT.		159.0	5.0	97%	149.0	3.0	98%
NOV.		160.0	11.8	93%	104.0	11.0	89%
DEC.		154.0	4.5	97%	159.0	3.0	98%
Average		145.9	5.1	97%	142.3	6.0	96%
Objective			15.0			15.0	
Limit			25.0			25.0	





# CATARAQUI BAY Wastewater Treatment Plant 2018 ANNUAL REPORT Monthly Graphs





# CATARAQUI BAY Wastewater Treatment Plant


## 2018 ANNUAL REPORT

### Monthly data

Month	Unit	Final Effluent results		
		Raw sewage Free Ammonia (NH <sub>3</sub> )	Final Effluent Ammonia (NH <sub>3</sub> +NH <sub>4</sub> )	Final Effluent Nitrites & nitrates
		mg/L	mg/L	mg/L
JAN.		0.40	8.59	11.5
FEB.		0.35	5.13	10.8
MAR.		0.55	8.97	8.4
APR.		0.54	12.31	3.9
MAY		0.44	18.95	1.7
JUN.		0.37	17.85	4.7
JUL.		0.53	13.03	7.2
AUG.		0.45	9.51	9.3
SEP.		0.62	11.43	7.4
OCT.		1.06	3.56	12.9
NOV.		0.45	6.29	8.3
DEC.		0.48	11.08	6.2
Average Objective Limit		0.52	10.56 Variable	7.69



# CATARAQUI BAY Wastewater Treatment Plant 2018 ANNUAL REPORT Monthly Graphs





# CATARAQUI BAY Wastewater Treatment Plant

## 2018 ANNUAL REPORT


### Monthly data

#### Aluminum Sulphate

Month	Unit	C Plant Litres / day	C Plant mg/l	D Plant Litres / day	D Plant mg/l
JAN.		249	21	302	21
FEB.		228	16	235	16
MAR.		216	18	286	18
APR.		276	15	226	15
MAY		211	14	165	14
JUN.		218	16	169	15
JUL.		223	19	153	16
AUG.		242	17	162	14
SEP.		206	20	148	15
OCT.		220	18	136	12
NOV.		246	17	129	11
DEC.		238	15	121	9
Average		231	17	186	15



# CATARAQUI BAY Wastewater Treatment Plant 2018 ANNUAL REPORT Monthly Graphs





# CATARAQUI BAY Wastewater Treatment Plant


## 2018 ANNUAL REPORT

### Monthly data

Month	Bacterial results					
	Unit	Final Effluent E. Coli. counts / 100mL	E-Coli Objective counts / 100mL	Final Effluent Total Coliforms (second axis) counts / 100mL	Final Effluent Fecal Streptococci counts / 100mL	Final Effluent Acute lethality to trout pass / fail
JAN.		10	200	6,100	1,320	
FEB.		140	200	31,000	1,860	pass
MAR.		84	200	6,000	2,440	
APR.		100	200	19,850	3,910	
MAY		393	200	18,250	3,530	
JUN.		6	200	850	290	fail
JUL.		6	200	1,100	390	pass
AUG.		30	200	7,400	700	
SEP.		10	200	1,850	60	
OCT.		96	200	9,100	1,200	pass
NOV.		44	200	11,350	2,310	pass
DEC.		16	200	4,050	640	pass
Average		77.92		9,741.67	1,554.17	
Objective		200				



# CATARAQUI BAY Wastewater Treatment Plant 2018 ANNUAL REPORT Monthly Graphs







# CATARAQUI BAY Wastewater Treatment Plant

## 2018 ANNUAL REPORT


### Monthly data

#### Sodium hypochlorite

Month	Unit	Dosage Kg / day	Dosage kg/month	Dosage mg/L	Residual mg/L
JAN.		54	1,658	1.72	0.30
FEB.		36	1,018	1.09	0.33
MAR.		37	1,137	1.23	0.30
APR.		27	815	0.70	0.31
MAY		23	726	0.88	0.32
JUN.		50	1,493	2.15	0.38
JUL.		39	1,212	1.90	0.38
AUG.		45	1,382	1.72	0.34
SEP.		69	2,075	3.13	0.36
OCT.		55	1,708	2.10	0.31
NOV.		51	1,524	1.63	0.32
DEC.		44	1,365	1.33	0.35
Average		44	1,342.75	1.63	0.33



# CATARAQUI BAY Wastewater Treatment Plant 2018 ANNUAL REPORT Monthly Graphs





# CATARAQUI BAY Wastewater Treatment Plant

## 2018 ANNUAL REPORT


### Monthly data

#### Calcium Thiosulphate

Month	Unit	Dosage Litres / day	Dosage Litres / month	Dosage mg / L	Residual mg / L	Compliance Yes / No
JAN.		233	7,211	7.40	0.0	yes
FEB.		216	5,393	7.50	0.0	yes
MAR.		225	6,988	7.60	0.0	yes
APR.		278	8,343	7.10	0.0	yes
MAY		211	6,554	7.90	0.0	yes
JUN.		232	6,938	9.90	0.0	yes
JUL.		165	5,126	8.20	0.0	yes
AUG.		179	5,555	7.40	0.0	yes
SEP.		183	5,491	8.30	0.0	yes
OCT.		120	3,721	4.80	0.0	yes
NOV.		195	5,850	6.20	0.0	yes
DEC.		133	4,113	4.20	0.0	yes
Average		198	5,940	7.21	0.0	



# CATARAQUI BAY Wastewater Treatment Plant 2018 ANNUAL REPORT Monthly Graphs





# CATARAQUI BAY Wastewater Treatment Plant

## 2018 ANNUAL REPORT


### Monthly data

Month	Unit	*Digested sludge *Sludge		*Sludge Cake	
		processed (Estimated) M3 / Month	Total solids in sludge %	Sludge Cake output M3 / Month	Total solids in sludge cake %
JAN.		2480	2.2%	N/A	N/A
FEB.		2240	2.3%	N/A	N/A
MAR.		2480	2.4%	N/A	N/A
APR.		2400	2.7%	N/A	N/A
MAY		2480	1.9%	N/A	N/A
JUN.		2400	1.5%	N/A	N/A
JUL.		2480	1.8%	N/A	N/A
AUG.		2480	1.8%	N/A	N/A
SEP.		2400	3.7%	N/A	N/A
OCT.		2480	1.8%	N/A	N/A
NOV.		2400	1.9%	N/A	N/A
DEC.		2480	2.2%	N/A	N/A
Average		2,433	2.2%		
		29200			

\*Sludge Processed based on hauled sludge estimate of 80 m3/day transported to Ravenview for Sludge Cake Production at that location during construction



# CATARAQUI BAY Wastewater Treatment Plant 2018 ANNUAL REPORT Monthly Graphs





# CATARAQUI BAY Wastewater Treatment Plant

## 2018 ANNUAL REPORT

### Monthly data


#### Effluent Summary from daily samples

Month	Final Effluent pH	Final Effluent pH lower limit	Final Effluent pH top limit	Final Effluent Temperature	Eff Chlorine residual
	Unit			degrees Celcius	mg / L (second axis)
JAN.	7.79	6.5	9	11.40	0.0
FEB.	7.79	6.5	9	11.60	0.0
MAR.	7.85	6.5	9	12.00	0.0
APR.	7.96	6.5	9	12.70	0.0
MAY	7.92	6.5	9	16.00	0.0
JUN.	7.82	6.5	9	17.60	0.0
JUL.	7.85	6.5	9	21.00	0.0
AUG.	7.82	6.5	9	21.50	0.0
SEP.	7.84	6.5	9	20.70	0.0
OCT.	7.77	6.5	9	17.70	0.0
NOV.	7.77	6.5	9	15.40	0.0
DEC.	7.90	6.5	9	13.07	0.0
Average	7.8			15.89	0.00





# CATARAQUI BAY Wastewater Treatment Plant 2018 ANNUAL REPORT Monthly Graphs





# CATARAQUI BAY Wastewater Treatment Plant


## 2018 ANNUAL REPORT

### Monthly data

Month	Unit	TKN / Influent pH / Phosphorus					
		Influent	Final Effluent	Influent	Influent	Final Effluent	Removal
		TKN mg / L	TKN mg / L	pH	Phosphorus mg / L (second axis)	Phosphorus mg / L (second axis)	Phosphorus %
JAN.		31.26	9.56	7.54	3.20	0.26	92%
FEB.		27.20	7.23	7.56	2.90	0.39	87%
MAR.		27.48	11.30	7.75	2.50	0.52	79%
APR.		25.48	13.90	7.79	2.40	0.20	92%
MAY		30.46	19.62	7.61	2.90	0.34	88%
JUN.		38.43	18.58	7.47	3.90	0.35	91%
JUL.		42.35	14.90	7.49	4.30	0.46	89%
AUG.		37.38	9.72	7.63	3.60	0.36	90%
SEP.		40.58	13.63	7.59	3.60	0.51	86%
OCT.		44.56	5.16	7.59	4.70	0.48	90%
NOV.		29.18	9.30	7.65	2.50	0.59	76%
DEC.		31.30	12.70	7.65	2.70	0.25	91%
Average		33.81	12.13	7.61	3.27	0.39	88%
Objective						1.0	
Limit						1.0	



# CATARAQUI BAY Wastewater Treatment Plant 2018 ANNUAL REPORT Monthly Graphs





# CATARAQUI BAY Wastewater Treatment Plant


## 2018 ANNUAL REPORT

### Monthly data

effluent flow		Flows				
		Monthly	Monthly	Monthly	Monthly	Monthly
Month	Unit	Minimum Flow	Rated capacity Flow	Maximum Flow	Average Flow	Total Flow
		m3 / day	m3 / day	m3 / day	m3 / day	m3 / Month
JAN.		21,566	38,800	94,957	32,349	1,002,828
FEB.		21,536	38,800	77,526	34,301	960,429
MAR.		23,946	38,800	42,491	30,632	949,582
APR.		26,617	38,800	76,326	39,307	1,179,202
MAY		22,499	38,800	36,418	26,883	833,385
JUN.		16,076	38,800	39,164	23,334	700,019
JUL.		16,403	38,800	32,882	20,608	638,860
AUG.		19,302	38,800	49,122	25,910	803,196
SEP.		19,428	38,800	34,243	22,555	676,654
OCT.		19,652	38,800	37,657	25,775	799,030
NOV.		24,319	38,800	62,132	31,904	957,116
DEC.		23,576	38,800	77,442	34,551	1,071,082
Average Objective Limit		21,243	38,800	55,030	29,009	880,949



# CATARAQUI BAY Wastewater Treatment Plant 2018 ANNUAL REPORT Monthly Graphs





# CATARAQUI BAY Wastewater Treatment Plant

## 2018 ANNUAL REPORT

### Monthly data

Month	Digester gas production		
	Gas production	Gas to boilers	Gas to flare
Unit	M3 / Month	M3 / Month	M3 / Month
JAN.	54,299	26,448	27,851
FEB.	43,037	23,740	19,297
MAR.	63,564	25,325	38,239
APR.	68,806	24,321	44,485
MAY	61,040	24,701	36,339
JUN.	59,033	23,754	35,279
JUL.	54,126	22,281	31,845
AUG.	44,081	20,470	23,611
SEP.	43,054	18,390	24,664
OCT.	54,080	21,508	32,572
NOV.	52,026	24,302	27,724
DEC.	56,359	23,828	32,531
Average	54,459	23,255.7	31,203.1
<b>Total</b>	<b>653,505</b>	<b>279,068</b>	<b>374,437</b>



# CATARAQUI BAY Wastewater Treatment Plant 2018 ANNUAL REPORT Monthly Graphs

